



Shealy Electric Wholesale
422 Fairforest Way
Greenville SC 29607

Subject: FIELD NOTICE / PRODUCT RECALL
- LOAD BREAK SWITCH TYPE LBS 60 TO 125A

Dear Sir or Madam,

We are informing you of the potential for failure in the Load Break Switch Types LBS 60 to 125A. The potential for failure exist in the following switch part numbers manufactured from January 1, 2007 through December 15, 2007 and in those enclosed switches containing the identified switches;

Switch Part Nbrs.	Enclosed Switch Part Nbrs.
LBSR100	EALBS1003BS0 ECLBS603BP0
LBSR100DH	EALBS1253RS0 ECLBS603RP0
LBSR125	EALBS803RS0N ECLBS603RS0
LBSR125DH	EBLBS1003BP0 EDLBS603BP0
LBSR60	EBLBS1003RP0 EDLBS603BP1
LBSR60DH	EBLBS1253RP0 EDLBS603BS0
LBSR80	EBLBS603BP0 EDLBS603RP0
LBSR80DH	EBLBS603RP0 EDLBS603RS0
LBS1100	EBLBS603RS0 EDLBS603RS1
LBS1125	EBLBS603RS3 EDLBS603RS3
LBS160	EBLBS803RS3 EGLBS1003BS0
LBS180	ECLBS1003RS16 EGLBS1003RS0
	EGLBS1253RS0

The manufacturing date (week year) is marked on the switch.

The problem centers on a non compliant internal plastic part. There is the potential for this component to break leaving one or more poles of the switch in the ON position. The pole may remain electrically connected even if the switch is in the O (OFF) position.

This deviation presents a potential danger for the end user in the field. The malfunction may even cause danger to life during electrical installation and maintenance work

To remedy this problem promptly and in the best conditions, we have set up the following procedures which need your active participation.

- As an immediate precaution please instruct all your customers:
- to check with care that electrical circuits are fully disconnected (using a volt meter) before making any electrical installation or maintenance work
 - and to make sure that all your customers and end users have received this notice.



Ferraz Shawmut
374 Merrimac Street • Newburyport, MA 01950-1998
Phone: 978-462-6662 • Fax: 978-462-0181 • us.ferrazshawmut.com

CARBONE LOWVOLTAGE

1) RECALL OF PRODUCTS in the WAREHOUSE

- All products identified under this Field Notification and Recall must not be used, and must be available for return. Please communicate to us the quantities on hand, so that we can organize the free replacement of the products.

- This procedure also concerns the products in your customers' possession.

It is essential that you take all necessary steps to hold any shipments of affected products. Moreover, it is also crucial that you issue a warning letter to your clients requesting them as well to pull their own stock of involved products.

2) RECALL OF PRODUCTS in the FIELD

Please inform your customers of this Field Notification and Recall, and please take all necessary steps to remove and to replace the products in the field

You will be informed as soon as possible about when we will be able to deliver replacement products to your company. The replacement product will be provided at no cost.

We have established a dedicated phone line and email address to facilitate communication between your company and Ferraz Shawmut concerning this notice. Please contact us at

Phone Number:1-(978) 457-4285

Email LBS.HELP@ferrazshawmut.com

Best regards

A handwritten signature in black ink, appearing to read "Michael J. Fitzgerald".

Michael J. Fitzgerald
Director of Quality Assurance
Ferraz Shawmut, North America