

ARTICLE 404


SWITCHES

Introduction to Article 404—Switches

The requirements of Article 404 address switches of all types including snap (toggle) switches, dimmer switches, fan switches, knife switches, circuit breakers, and automatic switches such as time clocks and timers.

404.4 Damp or Wet Locations


(A) Surface-Mounted Switches or Circuit Breakers. Surface-mounted switches and circuit breakers in a damp or wet location must be installed in a weatherproof enclosure. ▶Figure 404-11




▶Figure 404-11

(B) Flush-Mounted Switches or Circuit Breakers. A flush-mounted switch or circuit breaker in a damp or wet location must have a weatherproof cover. ▶Figure 404-12

(C) Switches Within Tub or Shower Spaces. Switches must not be installed within tub or shower spaces unless installed as part of a listed tub or shower assembly. ▶Figure 404-13



▶Figure 404-12



▶Figure 404-13